

## MODEL SEG-7 - Return Performance Data

Nominal Size		Nom Duct Area, ft2	Core Vel, fpm Ps	400	500	600	700	800	900
W Width	H Height			<20	<20	<20	<20	<20	<20
6"	6"	0.25	CFM	60	80	90	110	130	140
			NC	<20	<20	<20	<20	<20	<20
8"	8"	0.44	CFM	130	160	190	220	250	280
			NC	<20	<20	<20	<20	<20	20
10"	8"	0.56	CFM	160	210	250	290	330	370
			NC	<20	<20	<20	<20	<20	21
10"	10"	0.69	CFM	210	270	320	370	430	480
			NC	<20	<20	<20	<20	<20	22
12"	12"	1.00	CFM	320	400	480	560	640	720
			NC	<20	<20	<20	<20	20	24
14"	14"	1.36	CFM	450	560	680	790	900	1020
			NC	<20	<20	<20	<20	22	25
18"	14"	1.75	CFM	590	740	890	1040	1190	1330
			NC	<20	<20	<20	<20	23	27
18"	18"	2.25	CFM	780	970	1170	1360	1560	1750
			NC	<20	<20	<20	20	24	28
20"	20"	2.78	CFM	980	1220	1460	1710	1950	2200
			NC	<20	<20	<20	21	25	29
24"	24"	4.00	CFM	1440	1800	2160	2520	2880	3230
			NC	<20	<20	<20	23	27	31
32"	32"	7.11	CFM	2630	3280	3940	4600	5250	5910
			NC	<20	<20	20	25	29	33

Data determined in accordance with ANSI/ASHRAE Standard 70-1991

Data based on Actual Neck Size = Nominal Neck Size - 1/4"

Ps - Static Pressure, inches w.g.

NC - Noise Criteria based on room attenuation of 10 dB



**KEES INCORPORATED**  
400 S. Industrial Dr.  
Elkhart Lake, WI 53020

Phone: (920) 876-3391  
Fax: (920) 876-3065  
Website: [www.kees.com](http://www.kees.com)